

IEC**IECEE**

®

TM

Ref. Certif. No.

HU-003325

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Moulded Case Circuit Breaker

Name and address of the applicant

HIMEL HONG KONG LIMITED
11/F KERRY CTR
683 KING'S RD QUARRY BAY, Hong Kong

Name and address of the manufacturer

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park,
Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China

Name and address of the factory

See additional page(s)

Ratings and principal characteristics

Cat. B; 3P, 4P; Ue=400/415VAC; 690VAC, 50/60Hz;
In= 630/800/1000/1250/1600A, electronic type;
Ui=1000V; Uimp=12,0kV; Icu= 50kA(400/415V); 35kA(690V);
Ics=100%Icu; Icw=42kA/1s(400/415V); 35kA/1s(690V);

Trademark (if any)

HIMEL

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

HDM3E-1600M

Additional information (if necessary may also be reported on page 2)

Detailed information refer to test report 60438070 002.

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

60438070 002

This CB Test Certificate is issued by the National Certification Body

**TÜVRheinland**®TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2021-02-23

Signature:

Wencai Zhang

1. DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China
2. DELIXI ELECTRIC (WUHU) LTD
Wuhu Machinery Industrial Park,
Wuhu city
241100 Anhui
P.R. China

Additional information (if necessary)

Report Ref. No. : 60438070 002



Date: 2021-02-23

Signature:

Wencai Zhang