

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers

Name and address of the applicant

HIMEL HONG KONG LIMITED
11/F Kerry Crt 683 King's Rd Quarry Bay Hong Kong

Name and address of the manufacturer

DELIXI ELECTRIC LTD.
Delixi High Tech Industrial Park Liushi Town, Yueqing City,
Zhejiang Province, China 325604

Name and address of the factory
Note: When more than one factory, please report on page 2

See page 2

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

HDM2-125***

Additional information (if necessary may also be reported on page 2)

See page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015 +A1

As shown in the Test Report Ref. No. which forms part of this Certificate

200302553SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek

Signature:

Leif Mattsson

Date: 04 May, 2020

Factories

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City,
Zhejiang Province, China 325604

DELIXI ELECTRIC (WUHU) LTD.
Wuhu Machinery Industrial Park, Wuhu City
Anhui Province, China 241100

Ratings and principal characteristics

Ue= 220/240V for 1P;
Ue= 220/240/400V for 2P;
In= 10, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A;
Icu=20kA/220/240V, Ics=15kA/220/240V for 1P
Icu=30kA/220/240V, Ics=18kA/220/240V, Icu=20kA/400V, Ics=15kA/400V for 2P
Cat: A, li=10In, Uimp=8kV, Ui=690V, 50/60Hz

Additional information (if necessary)

Explanation of the type design:

HD M 2 - 125 * * *
(I) (II) (III) (IV) (V) (VI) (VII)

- I Himel
- II MCCB
- III design Number
- IV frame size
- V breaking class: L
- VI rated current: 10, 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A
- VII number of pole; 1, 2

Date: 04 May, 2020

Signature: 