



Ref. Certif. No.

HU-002178

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit breaker for overcurrent protection

Name and address of the applicant

HIMEL TECHNOLOGY, S.L.
calle Bac de Roda, No.52, edificio A,
08019 Barcelona, Spain

Name and address of the manufacturer

HIMEL TECHNOLOGY, S.L.
calle Bac de Roda, No.52, edificio A,
08019 Barcelona, Spain

Name and address of the factory

See on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ue: 240/415V AC (1P); 240V AC (1P+N);
415V AC (2P/3P/3P+N/4P); 50/60Hz;
In:1/2/3/4/5/6/8/10/13/16/20/25/32/40/50/63A;
B/C/D-type; Icn=Ics=4,5kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

HDB3wHL

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

03401-2018055A-S-A2

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu



Gabor Kassai

Signature:

Gabor Kassai

Date: 2018-03-09

Factories:

- 1) DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town,
Yueqing City, Zhejiang Province,
China 325604
- 2) DELIXI ELECTRIC (WUHU) LTD
Wuhu Machinery Industrial Park, Wuhu city,
Anhui Province, China 241100

Additional information (if necessary)



Date: 2018-03-09

TÜV Rheinland InterCert Kft., Division MEE
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Signature:

A handwritten signature in blue ink, appearing to read "Kassai", written over a circular blue stamp.

Gabor Kassai

