



Ref. Certif. No.

HU-002540

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit breaker for overcurrent protection

Name and address of the applicant

DELIXI ELECTRIC LTD  
Delixi High Tech Industrial Park, Liushi Town,  
Yueqing City, Zhejiang Province,  
China 325604

Name and address of the manufacturer

DELIXI ELECTRIC LTD  
Delixi High Tech Industrial Park, Liushi Town,  
Yueqing City, Zhejiang Province,  
China 325604

Name and address of the factory

See on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ue: 240/415V AC (1P); 240V AC (1P+N);  
415V AC (2P/3P/3P+N/4P); 50/60Hz;  
In:1/2/3/4/5/6/8/10/13/16/20/25/32/40/50/63A;  
B/C/D-type; Icn=Ics=6kA; Class 3

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

---

Model / Type Ref.

HDB3wHN

Additional information (if necessary may also be reported on page 2)

---

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015  
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

1W181255-B1

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI  
H-1132 Budapest, Váci út 48/A-B  
www.tuv.com



Date: 2019-04-02

Signature:

Gabor Kassai



Ref. Certif. No.

HU-002540

Factories:

- 1) DELIXI ELECTRIC LTD  
Delixi High Tech Industrial Park, Liushi Town,  
Yueqing City, Zhejiang Province,  
China 325604
- 2) DELIXI ELECTRIC (WUHU) LTD  
Wuhu Machinery Industrial Park, Wuhu city,  
Anhui Province, China 241100

**Additional information (if necessary)**



Date: 2019-04-02

TÜV Rheinland InterCert Kft., Division MEEI  
H-1132 Budapest, Váci út 48/A-B  
www.tuv.com

Signature:

Gabor Kassai

