

HU-002635

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Moulded-Case Circuit Breaker

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town,
Yueqing City, Zhejiang Province,
China 325604

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town,
Yueqing City, Zhejiang Province,
China 325604

See on page 2

Cat. A; Ue=230V AC(1P), 400V AC(2P, 3P, 4P); 50/60Hz; In=63A, 80A, 100A, 125A; Ui=500V; Uimp=4,0kV; Instantaneous tripping curve: Ii=6In(for B-type); Ii=8,5In(for C-type), Ii=12In(for D-type); Icu=10kA; Ics=75%Icu




HDB3w-125H

IEC 60947-2:2006 + AMD1:2009 + AMD2:2013

1C141365-M1.01

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., Division M H-1132 Budapest, Váci út 48/A-B

www.tuv.com

Signature:

Zanca duct Certification

Date: 2019-06-25



HU-002635

Factories:

- 1) DELIXI ELECTRIC LTD
 Delixi High Tech Industrial Park, Liushi Town,
 Yueqing City, Zhejiang Province, China 325604
- 2) DELIXI ELECTRIC (WUHU) LTD Wuhu Machinery Industrial Park, Wuhu city, Anhui Province, China 241100

Additional information (if necessary)



Date:: 2019-06-25

TÜV Rheinland InterCert Kft., Division ME H-1132 Budapest, Váci út 48/A-B www.tuv.com

Signature:

Gabor Kassa For Certification