



Ref. Certif. No.

HU-002636

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded-Case Circuit Breaker

Name and address of the applicant

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town,
Yueqing City, Zhejiang Province,
China 325604

Name and address of the manufacturer

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town,
Yueqing City, Zhejiang Province,
China 325604

Name and address of the factory

See on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Cat. A; Ue=230V AC(1P), 400V AC(2P, 3P, 4P); 50/60Hz;
In=63A, 80A, 100A, 125A; Ui=500V; Uimp=4,0kV;
Instantaneous tripping curve: Ii=6In(for B-type);
Ii=8,5In(for C-type), Ii=12In(for D-type);
Icu=6kA; Ics=100%Icu

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

HDB3w-125N

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2006 + AMD1:2009 + AMD2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

1C141365-M1.02

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com



Date: 2019-06-25

Signature:

Gabor Kassai



Ref. Certif. No.

HU-002636

Factories:

- 1) DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town,
Yueqing City, Zhejiang Province, China 325604

- 2) DELIXI ELECTRIC (WUHU) LTD
Wuhu Machinery Industrial Park, Wuhu city,
Anhui Province, China 241100

Additional information (if necessary)



Date: : 2019-06-25

TÜV Rheinland InterCert Kft., Division MEEL
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

Signature:



Gabor Kassai