

ATTESTATION OF CONFORMITY

Issued to: DELIXI ELECTRIC LTD
Delixi High-Tech Industrial Park, Liushi Town, Yueqing City
325604 Zhejiang Province, China

For the product: Circuit breakers for overcurrent protection

Trade name: Himel

Type/Model: HDB9N

Ratings: 1P, 2P, 3P, 4P
Ue: 230/400 Vac (1P); 400 Vac (2P, 3P, 4P); 50/60 Hz
In = 1, 2, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63 A; B, C and D – type
Ics = Icn = Icn1 = 6 kA
Uimp= 4 kV, Grid distance “a”= 35 mm
Energy limiting class 3 for B and C type

Manufactured by: DELIXI ELECTRIC LTD
Delixi High-Tech Industrial Park, Liushi Town, Yueqing City
325604 Zhejiang Province, China

Subject: Type Test

Requirements: EN 60898-1:2019, IEC 60898-1:2015

Remark: This Attestation is based on AoC no. 3315402.02A issued on 2019-06-05.
This Attestation replaces AoC no. 3310161.01A issued on 2016-07-21.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a reports no 3315404.51 issued on 2019-06-11, 3315402.50 issued on 2019-04-23, 3307909.51 issued on 2015-06-29 and 3303848.50/51 issued on 2012-10-10.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 21 June 2019

Number: 3315404.02A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed
The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

