



Ref. Certif. No.

HU-003612

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Moulded case circuit breaker
Name and address of the applicant	HIMEL HONG KONG LIMITED 11/F KERRY CTR 683 KING'S RD QUARRY BAY, Hong Kong
Name and address of the manufacturer	HIMEL HONG KONG LIMITED 11/F KERRY CTR 683 KING'S RD QUARRY BAY, Hong Kong
Name and address of the factory	Zhejiang ETK Electric Co.,Ltd Qianxizhang Village, Beibaixiang Town, Yueqing City, Zhejiang, P.R. China
Ratings and principal characteristics	Ui:1000V; Uimp:12kV; Reference temperature:+40°C,+50°C; 3P; Cat.A; In:800/1000/1250/1600A; Ue:AC400/415V,AC500V,AC690V; HDM3-1600F:Ics/Icu:400/415V:36/50kA; 500V,690V:20/30kA; HDM3-1600N:Ics/Icu:400/415V:50/70kA; 500V,690V:20/30kA
Trademark (if any)	Himel
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	HDM3-1600F , HDM3-1600N
Additional information (if necessary may also be reported on page 2)	Detailed information refer to test report CN21279X 003.
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN21279X 003

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web:www.tuv.com

Date: 2021-09-09

Signature: Wencai Zhang