

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fuses with fuse-links having cylindrical contact caps

Name and address of the applicant

DELIXI Group Co., Ltd.
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang
Province, P.R.China

Name and address of the manufacturer

DELIXI Group Co., Ltd.
(Delixi Mansion) No.1 Liuqing Road, Liushi Town, Yueqing, Zhejiang
Province, P.R.China

Name and address of the factory

DELIXI Group Co., Ltd.
No.165 Great Bridge Road, Liushi Town, Yueqing City, Zhejiang Province,
P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Fuse-links: HRT18-32; Un:AC380V,AC500V;
In:2A,3A,4A,5A,6A,8A,10A,12A,16A,20A,25A,32A; Rated breaking
capacity I1:100kA; Breaking range and utilization category: gG;
Fuse-holders: HRT18-32,HRT18-32X; Uimp: 4kV; Un:AC380V,AC500V;
In:32A; 1P,2P,3P,4P

Trademark (if any)

Himel

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

RT18-32(Fuse-links), RT18-32, RT18-32X(Fuse-holders)

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60269-2:2013(5th Edition) in conjunction with IEC 60269-1:2006 (Fourth Edition) + A1:2009

As shown in the Test Report Ref. No. which forms part of this Certificate

03601-A-18CB0107-S-A;03601-A-18CB0107-S-B

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Mar.19,2019

Signature:

陆梅

Lu Mei

