



Reference No. SE-S-2200015

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's)

Type designation:	HDB3LE, HDB3LEG
-------------------	-----------------

Certificate holder: HIMEL HONG KONG LIMITED

11/F Kerry Ctr 683 King's Rd Quarry Bay,

Hong Kong

The product complies with

the standard(s):

EN 61009-1:2012+A1+A2+A11+A12

Date of expiry: 09 August, 2026

EU Directive information: According to the principle of presumption of conformity, this certificate

constitutes support for an EC Declaration of Conformity and CE marking

according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 05 January, 2022

Henrik Wikström

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement, Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 1 of 2



APPENDIX:

Reference No. SE-S-2200015

Technical Data:

Type designation HDB3LE, HDB3LEG

Rated voltage (V): 240V or 230V for 2P(1P+N), 415V or 400V for 3P, 4P(3P+N)

Rated current (A): 6, 10, 16, 20, 25, 32, 40, 50, 63A

Rated Residual Operating

Current (mA): 10mA(only for 2P), 30mA, 50mA, 75mA, 100mA, 300mA

IP-Class 20 Frequency (Hz) 50/60

Poles No 2P(1P+N), 3P, 4P(3P+N)

Test Report 211201643SHA-001, 211201643SHA-002

Trademark Himel

Product information Type-AC & -A; B- & C- & D- type

Ics=Icn= 6000A, $I\Delta m = 2000A$

Manufacturing Sites: DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park Liushi Town, Yueqing City, Zhejiang Province, China 325604

DELIXI ELECTRIC (WUHU) LTD. Wuhu Machinery Industrial Park

Wuhu City, Anhui Province, China 241100

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 05 January, 2022

Henrik Wikström

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 2 of 2