


CERTIFICATE
FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2101711

**Residual current operated circuit-breakers
with integral overcurrent protection for
household and similar uses (RCBO's)**

Type designation: HDB3PLE, HDB3PLEG
Certificate holder: HIMEL HONG KONG LIMITED
11/F Kerry Crt 683 King's Rd Quarry Bay,
Hong Kong

**The product complies with
the standard(s):** EN 61009-1:2012+A1+A2+A11+A12

Date of expiry: 27 December, 2026

EU Directive information: According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 27 December, 2021

Quan Li

APPENDIX:

Reference No. SE-S-2101711

Technical Data:

Type designation	HDB3PLE, HDB3PLEG
Rated voltage (V)	240 or 230
Rated current (A)	6, 10, 16, 20, 25, 32, 40A
Rated Residual Operating Current (mA)	30mA
Frequency (Hz)	50/60
Poles No.	1P+N
Trademark	
Test Report	211201654SHA-001
Product information	Type-AC; C- & D- type, Ics=Icn= 4500A, IΔm= Im= 2000A

Manufacturing Sites:

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City,
Zhejiang Province, China 325604

DELIXI ELECTRIC (WUHU) LTD
Wuhu Machinery Industrial Park, Wuhu City, Anhui Province, China 241100

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 27 December, 2021

Quan Li

Intertek