



Ref. Certif. No.

CN35346

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

Circuit-breaker Incorporating Residual Current Protection

Name and address of the applicant  
Nom et adresse du demandeur

HIMEL TECHNOLOGY S.L.

Calle Bac de Roda No.52, Edificio A, 08019 BARCELONA, Spain

Name and address of the manufacturer  
Nom et adresse du fabricant

DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park, Liushi Town, Yueqing City,  
Zhejiang Province, China 325604

Name and address of the factory  
Nome et adresse de l'usine

DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park, Liushi Town, Yueqing City,  
Zhejiang Province, China 325604

Note: When more than one factory, please report on page 2  
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)  
Marque de fabrique (si elle existe)

HIMEL

Model / Type Ref.  
Ref. De type

HDB3wLE-125,HDB3wLE-125G

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>ème</sup> page)

PUBLICATION

EDITION

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60947-2:2006 (4th Edition)

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

03601-A-15CB0046-S

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: 2015-10-09

Signature:

Wang Kejiao

Issued 2003-05  
China Quality Certification Centre  
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86-10-83886666  
Fax: +86-10-83886282

website  
www.cqc.com.cn

CB 0033048

Ui: 500V, Ue: AC230V(1P+N,2P), AC400V(3P,3P+N,4P);  
In: 63A, 80A, 100A, 125A;  
Thermal Magnetic Over-current Release; Utilization category: A;  
Electronic Residual Current Tripping Unit; Type AC;  
Icu: 10kA, Ics: 7.5kA, I $\Delta$ n: 30mA, 50mA, 75mA, 100mA, 300mA;  
I $\Delta$ m: 2.5kA, Tripping Class: 20;  
HDB3wLE-125: 1P+N(With one protective pole, Uninterrupted  
neutral), 2P, 3P, 3P+N(With three protective poles, Uninterrupted  
neutral), 4P;  
HDB3wLE-125G: 1P+N(With one protective pole, Uninterrupted  
neutral), 2P.

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2015-10-19

Signature: \_\_\_\_\_



Wang Kejiao