

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)

Name and address of the applicant

HIMEL HONG KONG LIMITED
11/F Kerry Crt 683 King's Rd Quarry Bay,
Hong Kong

Name and address of the manufacturer

DELIXI ELECTRIC LTD
Delixi High Tech Industrial Park, Liushi Town, Yueqing City,
Zhejiang Province, China 325604

Name and address of the factory

Note: When more than one factory, please report on page 2

See page 2

Ratings and principal characteristics

Un= 230V~ or 240V~, 1P+N, 50/60Hz
In= 6, 10, 16, 20, 25, 32, 40A, C- & D- type
IΔn= 30mA; Type-AC
Ics=Icn= 4500A, IΔm= Im= 2000A

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

HDB3PLE, HDB3PLEG

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010+A1+A2
IEC 61009-2-2:1991

As shown in the Test Report Ref. No. which forms part of this Certificate

211201654SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden**intertek**Signature: 

Date: 27 December, 2021

Quan Li

Factories

DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park, Liushi Town, Yueqing City,
Zhejiang Province, China 325604

DELIXI ELECTRIC (WUHU) LTD

Wuhu Machinery Industrial Park, Wuhu City, Anhui Province, China 241100

Date: 27 December, 2021

Signature: 