IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

|	
Product	Residual current operated circuit-breakers with integral overcurrent protection (RCBOs)
Name and address of the applicant	DELIXI ELECTRIC LTD Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, China 325604
Name and address of the manufacturer	DELIXI ELECTRIC LTD Delixi High Tech Industrial Park, Liushi Town, Yueqing City, Zhejiang Province, China 325604
Name and address of the factory Note: *When more than one factory, please report on page 2*	See on page 2
Ratings and principal characteristics	Ue = 240V~ (1P+N); 50/60Hz; (RCBO with one overcurrent protected pole and interrupted neutral) In = 6A, 10A, 16A, 20A, 25A, 32A, 40A; C-type, D-type Ics=Icn=4,5kA (HDB3wPLE); Ics=Icn=3kA (HDB3wPLEA); IΔn: 30mA, Type AC, IΔm: 3000A (See Test Report for further ratings)
Trademark (if any)	*Himel*
Customer's Testing Facility (CTF) Stage used	---
Model / Type Ref.	HDB3wPLE; HDB3wPLEA
Additional information (if necessary may also be reported on page 2)	---
A sample of the product was tested and found to be in conformity with	IEC 61009-1:2010 + AMD1:2012 + AMD2:2013 IEC 61009-2-2:1991 EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	1C14590-A1.01

This CB Test Certificate is issued by the National Certification Body

TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

Date: 2019-02-28   Signature: Tünde Potencsik

Factories:

1) DELIXI ELECTRIC LTD

   Delixi High Tech Industrial Park, Liushi Town,
   Yueqing City, Zhejiang Province,
   China 325604

2) DELIXI ELECTRIC (WUHU) LTD

   Wuhu Machinery Industrial Park, Wuhu city,
   Anhui Province, China 241100

Additional information (if necessary)

TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

Date: 2019-02-28

Signature: Tünde Potencsik