

Intertek Testing Services Ltd, Shanghai, ETL SEMKO
Building No. 86
1198 Qinzhou Road (North)
Caohejing Development Zone
Shanghai 200233
CHINA

Handled by
Susanna Ringnér
Direct telephone
+46 8 750 04 56
Reference
1410153
E-mail
susanna.ringner@intertek.com
Your Reference
Joyce Xu

6 August 2014

Intertek S Mark Certificate with No. 1410153

Thank You for S Marking your Products!

You have taken the first step to S Mark, but have you taken the next step by letting your customers know about your investment? When you use the S Mark in your marketing you are making clear that your company is truly committed to quality and safety. Positioning and differentiate yourself as a company which is dedicated to safety enables you to increase your sales – because in Europe safety sells.

The S Mark is highly recognized among retailers and authorities since 1926.

The S Mark also strengthens your brand by signaling that safety is important to your company and that you care about the safety of your clients. Since we value you as a customer we want to make sure you are getting the best value out of the S Mark. Many of our customers are already using the S Mark in their marketing. Popular media to use the mark is in campaigns, on packaging and in product catalogues. To find out more and to download tools, please visit www.sweden.intertek-etlsemko.com/smark.

**Intertek**

If you have any questions don't hesitate to contact us at info-sweden@intertek.com

Additional part of the certification

In addition to your product certification, we are conducting inspections at your manufacturing site/s. The inspections are carried out by our inspectors or subcontractors. For details of the technical requirements for these inspections, please contact inspection.etlsemko@intertek.com.

Your success is important to us!

Best Regards,

Göran Lilja
Executive Vice President
Intertek Semko AB

Certificate



for European Product Safety
Intertek

Reference No. 1410153

Moulded case circuit-breakers

Type designation HDB9Z

Certificate holder **HIMEL TECHNOLOGY, S.L.**
calle Bac de Roda, No. 52
edificio A 08019, Barcelona,
SPAIN

The product complies with the standard(s) EN 60947-2:2006+A1+A2

Date of expiry 6 August 2019

EU Directive information *The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.*

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed


Paul Klemets


Date 6 August 2014
Page 1 of 3





Intertek Appendix

Reference No. 1410153

Technical data

| | |
|-----------------------|---|
| Type designation/ | HDB9Z |
| Trade mark / |  |
| Rated Voltage (V) / | DC125V, DC250V |
| Rated Current (A) / | 1, 2, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A |
| Frequency (Hz) / | 50/60Hz |
| IP-class / | 20 |
| Poles No. / | 1P |
| Product information / | $I_{cs} = 7,5kA(DC125V)$, $I_{cu} = 10kA(DC125V)$, $I_{cs} = I_{cu} = 6kA(DC250V)$, Utilization category: A |

| | |
|-----------------------|---|
| Type designation/ | HDB9Z |
| Trade mark / |  |
| Rated Voltage (V) / | DC250V, DC500V |
| Rated Current (A) / | 1, 2, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A |
| Frequency (Hz) / | 50/60Hz |
| IP-class / | 20 |
| Poles No. / | 2P |
| Product information / | $I_{cs} = 7,5kA(DC250V)$, $I_{cu} = 10kA(DC250V)$, $I_{cs} = I_{cu} = 6kA(DC500V)$, Utilization category: A |

| | |
|-----------------------|---|
| Type designation/ | HDB9Z |
| Trade mark / |  |
| Rated Voltage (V) / | DC1000V |
| Rated Current (A) / | 1, 2, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A |
| Frequency (Hz) / | 50/60Hz |
| IP-class / | 20 |
| Poles No. / | 4P |
| Product information / | $I_{cs} = I_{cu} = 6kA$, Utilization category: A |

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.



Intertek
Appendix

Reference No. 1410153


Manufacturing site(s) Delixi Electric (Wuhu) Ltd.
Wuhu Machinery Industrial Park,
Wuhu City, Anhui Province 241100
CHINA

This certificate, which includes production control, constitutes sufficient support for an EC Declaration of Conformity and CE marking, according the principle of presumption of conformity, of the product according to the Low Voltage Directive 2006/95/EC.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed



Paul Klemets

Date 6 August 2014

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.