



BV LCIE  
CHINA  
Number

N° 1666AS04DEL20102

## ATTESTATION of conformity with European Directives

*Product:* **Switch-disconnector**  
*Reference:* **HDG3 Series**  
*Issued to:* **HIMEL TECHNOLOGY, S.L.**

*Address:* **calle Bac de Roda, No. 52, edificio A 08019 BARCELONA Spain**

*Manufacturer:* **DELIXI ELECTRIC LTD**

*Technical characteristics:*  
**Utilization category: AC-22A**  
**Ue: 230V for 1P, 400V for 2P, 3P, 4P**  
**Ie: 20A, 25A, 32A, 40A, 63A, 80A, 100A, 125A**  
**Ui: 500V; Uimp: 6kV**  
**Icw: 20Ie/1s; Icm: 28,1Ie**  
**Rated frequency: 50/60Hz**

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

**Low Voltage Directive 2014/35/EU**

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
<b>EN 60947-3: 2009+A1:2012</b> <b>EN 60947-1: 2007:A1:2011</b>	<b>B150073</b>	<b>07/04/2015</b>

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product  
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), ), April 20<sup>th</sup>, 2016.



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA  
必维欧亚电气技术咨询服务(上海)有限公司  
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,  
CaoHejing Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: [contact@cn.bureauveritas.com](mailto:contact@cn.bureauveritas.com)