



Reference No. SE-S-2100041

Thermal overload relay

Type designation: HDR3s-630/F

Certificate holder: HIMEL HONG KONG LIMITED

11/F KERRY CTR 683 KING'S RD QUARRY BAY

HONG KONG

The product complies with

the standard(s):

EN 60947-5-1:2017, EN IEC 60947-4-1:2019

Date of expiry: 13 January, 2026

EU Directive information:

According to the principle of presumption of conformity, this certificate constitutes support for an EC Declaration of Conformity and CE marking

according to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 13 January, 2021

Henrik Wikström

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 1 of 3



APPENDIX:

Reference No. SE-S-2100041

Technical Data:

Type designation HDR3s-630/F

Rated voltage (V) 690
Frequency (Hz) 50/60
IP-Class 20
Poles No. 3
Trademark

Test Report 201200603SHA-001, -002

Product information

Туре:	HDR3s-630/F	HDR3s-630/F		
Rating:	Ui= 690V, 3 poles, Uim	Ui= 690V, 3 poles, Uimp= 6kV, IP20, 50/60Hz		
Main circuit:				
Ue (V):	690	690		
Ie, AC-3 (A):	145-160-180-200	180-200-225-250	230-260-280-320	
	290-325-360-400	350-395-440-480	460-520-570-630	
Trip class:	10	10		
Ir (A):	18000	18000		
Iq (A):	50000	50000		
Auxiliary circuit:				
Ue (V):	AC 240	AC 415	DC 240	
Ie, (A):	AC-15: 1,64	AC-15: 0,95	DC-13: 0,23	
Ith (A):	6	6		

Manufacturing Sites: DELIXI ELECTRIC LTD

Delixi High Tech Industrial Park, Liushi Town, Yueqing City,

Zhejiang Province, China 325604

Intertek Semko AB Page 2 of 3



APPENDIX:

Reference No. SE-S-2100041

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity and CE marking according to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.



Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed: // /// **Date:** 13 January, 2021

Henrik Wikström

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Intertek Semko AB Page 3 of 3