



Ref. Certif. No.

HU-002176

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers with  
integral overcurrent protection (RCBOs)

Name and address of the applicant

HIMEL TECHNOLOGY, S.L.  
calle Bac de Roda, No.52, edificio A,  
08019 Barcelona, Spain

Name and address of the manufacturer

HIMEL TECHNOLOGY, S.L.  
calle Bac de Roda, No.52, edificio A,  
08019 Barcelona, Spain

Name and address of the factory

See on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ue = 240V~ (1P+N); 50/60Hz  
(RCBO with one overcurrent protected pole and  
interrupted neutral)  
In = 6A, 10A, 16A, 20A, 25A, 32A, 40A; C-type, D-type;  
Ics=Icn=4,5kA (HDB3wHPLE); Ics=Icn=3kA (HDB3wHPLEA);  
IΔn: 30mA, Type AC, IΔm: 3000A

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

---

Model / Type Ref.

HDB3wHPLE; HDB3wHPLEA

Additional information (if necessary may also be  
reported on page 2)

---

A sample of the product was tested and found  
to be in conformity with

IEC 61009-1:2010 + AMD1:2012 + AMD2:2013  
IEC 61009-2-2:1991  
EU Group Differences

As shown in the Test Report Ref. No. which forms part  
of this Certificate

1C14590-B1\_A1

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEE  
H-1132 Budapest, Váci út 48/A-B  
www.tuv.hu

Date: 2018-03-09

Signature:

Gabor Kassai





Ref. Certif. No.

HU-002176

Factories:

- 1) DELIXI ELECTRIC LTD  
Delixi High Tech Industrial Park, Liushi Town,  
Yueqing City, Zhejiang Province,  
China 325604
- 2) DELIXI ELECTRIC (WUHU) LTD  
Wuhu Machinery Industrial Park, Wuhu city,  
Anhui Province, China 241100

Additional information (if necessary)



Date: 2018-03-09

TÜV Rheinland InterCert Kft., Division MEE  
H-1132 Budapest, Váci út 48/A-B  
www.tuv.hu

Signature:



Gabor Kassai